



Certificate-SCBA Inspection



Breathing Apparatus Details.

| | | | |
|-------------|---------------------------------|------------------|---------------|
| Customer: | DPAB Co.Ltd Iraq Branch Block-9 | Certificate No.: | QC230725-041 |
| MFG: | Honeywell | Issue Date: | July 25, 2023 |
| Model No.: | NA | Due Date: | July 24, 2024 |
| Job Number: | QC/JN/23/00259 | S/No.: | 2207456188 |

Inspection Results:

| Parts | Inspection Items | Inspected | Remarks |
|---------------------|--|-----------|---------|
| Face Mask | Visor , Head Strep, Connector, cover of exhalation Valve, inhalation valve, leak tight silicon rubber, Oronasal guard, Reticulated hood. | √ | Pass |
| Demand Valve | Air supply Connector, Outer Shell, and Manual Switch off button, Manual force air supply button, Medium Pressure. | √ | Pass |
| Pressure Reducer | Working pressure form high Compressed to (0.7:1.25) MPa. | √ | Pass |
| Pressure Indicator | Taking random read and checking leak. | √ | Pass |
| Alarming Device | Test the alarm form 6 MPa to 0.25 MPa. | √ | Pass |
| Back Plate Assembly | Shoulder Strap, Back Plate Shoulder Strap fastener, Reducer Holder, Waist Belt, Cylinder Fastener. | √ | Pass |

Final Result:

- The inspected item/items is/are acceptable for use at the time it had been inspected.

- The equipment is/are in specification.
- This inspection was carried out in compliance with Sample Respiratory Protection Program as per (The Occupational Safety and Health Administration (OHSA)) 29CFR1910.134 Respiratory Protection Standard.
- This certificate may not be reproduced other than in full by photographic process.
- This certificate refers only to the particular item/items submitted for inspection.
- This certificate is valid only with signature and stamp.

Inspected By : Mahdi Haleem

