



Fire Extinguishers Inspection Report

Client:	DPAB Co.Ltd Iraq Branch Block-9	Job Number:	ATS-04-25-4953
Report Number:	ATS-04-25-4953-002	Location:	DQ Base – Basra / Block 9
Date of Inspection:	20- Apr-2025	Inspection Due Date:	19- Apr-2026

Relative Standard:	NFPA (National Fire Protection Association)- NFPA 10: Standard For Portable Fire Extinguisher
---------------------------	---

Environmental conditions during testing:	Humidity 41.0 % Rh ±3%	Temperatures Mean: 36.0°C ±5°C
---	------------------------	--------------------------------

#	Serial Number	Type	Weight	Re-filling	Condition		Remarks
					Acc.	Rej.	
1.	DQ-FE-026	Dry Powder	2 Kg	N/A	■	□	Accepted
2.	DQ-FE-027	Dry Powder	2 Kg	N/A	■	□	Accepted
3.	DQ-FE-028	Dry Powder	2 Kg	N/A	■	□	Accepted
4.	DQ-FE-029	Dry Powder	2 Kg	N/A	■	□	Accepted
5.	DQ-FE-030	Dry Powder	2 Kg	N/A	■	□	Accepted
6.	DQ-FE-031	Dry Powder	2 Kg	N/A	■	□	Accepted
7.	DQ-FE-032	Dry Powder	2 Kg	N/A	■	□	Accepted
8.	DQ-FE-033	Dry Powder	2 Kg	N/A	■	□	Accepted
9.	DQ-FE-034	Dry Powder	2 Kg	N/A	■	□	Accepted
10.	DQ-FE-035	Dry Powder	2 Kg	N/A	■	□	Accepted
11.	DQ-FE-036	Dry Powder	2 Kg	N/A	■	□	Accepted
12.	DQ-FE-037	Dry Powder	2 Kg	N/A	■	□	Accepted
13.	DQ-FE-038	Dry Powder	2 Kg	N/A	■	□	Accepted
14.	DQ-FE-039	Dry Powder	2 Kg	N/A	■	□	Accepted
15.	DQ-FE-040	Dry Powder	2 Kg	N/A	■	□	Accepted
16.	DQ-FE-041	Dry Powder	2 Kg	N/A	■	□	Accepted
17.	DQ-FE-042	Dry Powder	2 Kg	N/A	■	□	Accepted
18.	DQ-FE-043	Dry Powder	2 Kg	N/A	■	□	Accepted
19.	DQ-FE-044	Dry Powder	2 Kg	N/A	■	□	Accepted
20.	DQ-FE-045	Dry Powder	2 Kg	N/A	■	□	Accepted
21.	DQ-FE-046	Dry Powder	2 Kg	N/A	■	□	Accepted
22.	DQ-FE-047	Dry Powder	2 Kg	N/A	■	□	Accepted
23.	DQ-FE-048	Dry Powder	2 Kg	N/A	■	□	Accepted
24.	DQ-FE-049	Dry Powder	2 Kg	N/A	■	□	Accepted
25.	DQ-FE-050	Dry Powder	2 Kg	N/A	■	□	Accepted

*This is to Certify That: a competent person did attend the above-mentioned owner's work location on the date shown above and the fire extinguishers described in this report have been Examined as per the requirements of NFPA10 Standard. The results at the time of Inspection found **satisfactory** and the above-mentioned extinguishers considered **safe** to continue in service.*

Fire Extinguishers Inspected By:

Hussein Alaa / Master Log Certificate (NEBOSH 0136995/38678)

Date: 20/April/2025

Signature:



Reviewed & approved by: Hasan Omran

