



Fire Extinguishers Inspection Report

Client:	DPAB Co.Ltd Iraq Branch Block-9	Job Number:	ATS-04-25-4953
Report Number:	ATS-04-25-4953-005	Location:	DQ Base – Basra / Block 9
Date of Inspection:	20- Apr-2025	Inspection Due Date:	19- Apr-2026

Relative Standard:	NFPA (National Fire Protection Association)- NFPA 10: Standard For Portable Fire Extinguisher
---------------------------	---

Environmental conditions during testing:	Humidity 41.0 % Rh ±3%	Temperatures Mean: 36.0°C ±5°C
---	------------------------	--------------------------------

#	Serial Number	Type	Weight	Re-filling	Condition		Remarks
					Acc.	Rej.	
1.	DQ-FE-101	Dry Powder	2 Kg	N/A	■	□	Accepted
2.	DQ-FE-102	Dry Powder	2 Kg	N/A	■	□	Accepted
3.	DQ-FE-103	Dry Powder	2 Kg	N/A	■	□	Accepted
4.	DQ-FE-104	Dry Powder	2 Kg	N/A	■	□	Accepted
5.	DQ-FE-105	Dry Powder	2 Kg	N/A	■	□	Accepted
6.	DQ-FE-106	Dry Powder	2 Kg	N/A	■	□	Accepted
7.	DQ-FE-107	Dry Powder	2 Kg	N/A	■	□	Accepted
8.	DQ-FE-108	Dry Powder	2 Kg	N/A	■	□	Accepted
9.	DQ-FE-109	Dry Powder	2 Kg	N/A	■	□	Accepted
10.	DQ-FE-110	Dry Powder	2 Kg	N/A	■	□	Accepted
11.	DQ-FE-111	Dry Powder	2 Kg	N/A	■	□	Accepted
12.	DQ-FE-112	Dry Powder	2 Kg	N/A	■	□	Accepted
13.	DQ-FE-113	Dry Powder	2 Kg	N/A	■	□	Accepted
14.	DQ-FE-114	Dry Powder	2 Kg	N/A	■	□	Accepted
15.	DQ-FE-115	Dry Powder	2 Kg	N/A	■	□	Accepted
16.	DQ-FE-116	Dry Powder	8 Kg	N/A	■	□	Accepted
17.	DQ-FE-117	Dry Powder	8 Kg	N/A	■	□	Accepted
18.	DQ-FE-118	Dry Powder	8 Kg	N/A	■	□	Accepted
19.	DQ-FE-119	Dry Powder	8 Kg	N/A	■	□	Accepted
20.	DQ-FE-120	Dry Powder	8 Kg	N/A	■	□	Accepted
21.	DQ-FE-121	Dry Powder	8 Kg	N/A	■	□	Accepted
22.	DQ-FE-122	Dry Powder	8 Kg	N/A	■	□	Accepted
23.	DQ-FE-123	Dry Powder	8 Kg	N/A	■	□	Accepted
24.	DQ-FE-124	Dry Powder	8 Kg	N/A	■	□	Accepted
25.	DQ-FE-125	Dry Powder	8 Kg	N/A	■	□	Accepted

*This is to Certify That: a competent person did attend the above-mentioned owner's work location on the date shown above and the fire extinguishers described in this report have been Examined as per the requirements of NFPA10 Standard. The results at the time of Inspection found **satisfactory** and the above-mentioned extinguishers considered **safe** to continue in service.*

Fire Extinguishers Inspected By:

Hussein Alaa / Master Log Certificate (NEBOSH 0136995/38678)

Date: 20/April/2025

Signature:



Reviewed & approved by: Hasan Omran

