



Fire Extinguishers Inspection Report

Client:	DPAB Co.Ltd Iraq Branch Block-9	Job Number:	ATS-04-25-4953
Report Number:	ATS-04-25-4953-006	Location:	DQ Base – Basra / Block 9
Date of Inspection:	20- Apr-2025	Inspection Due Date:	19- Apr-2026

Relative Standard:	NFPA (National Fire Protection Association)- NFPA 10: Standard For Portable Fire Extinguisher
---------------------------	---

Environmental conditions during testing:	Humidity 41.0 % Rh ±3%	Temperatures Mean: 36.0°C ±5°C
---	------------------------	--------------------------------

#	Serial Number	Type	Weight	Re-filling	Condition		Remarks
					Acc.	Rej.	
1.	DQ-FE-126	Dry Powder	8 Kg	N/A	■	□	Accepted
2.	DQ-FE-127	Dry Powder	8 Kg	N/A	■	□	Accepted
3.	DQ-FE-128	Dry Powder	6 Kg	N/A	■	□	Accepted
4.	DQ-FE-129	Dry Powder	6 Kg	N/A	■	□	Accepted
5.	DQ-FE-130	Foam	25 L	N/A	■	□	Accepted
6.	DQ-FE-131	Dry Powder	2 Kg	N/A	■	□	Accepted
7.	DQ-FE-132	Dry Powder	2 Kg	N/A	■	□	Accepted
8.	DQ-FE-133	Dry Powder	2 Kg	N/A	■	□	Accepted
9.	DQ-FE-134	Dry Powder	2 Kg	N/A	■	□	Accepted
10.	DQ-FE-135	CO2	5 Kg	N/A	■	□	Accepted
11.	DQ-FE-136	CO2	5 Kg	N/A	■	□	Accepted
12.	DQ-FE-137	Water Based	25 L	N/A	■	□	Accepted
13.	DQ-FE-138	Water Based	25 L	N/A	■	□	Accepted
14.	DQ-FE-139	Dry Powder	6 Kg	N/A	■	□	Accepted
15.	DQ-FE-140	Dry Powder	6 Kg	N/A	■	□	Accepted
16.	DQ-FE-141	Dry Powder	25 Kg	N/A	■	□	Accepted
17.	DQ-FE-142	Dry Powder	25 Kg	N/A	■	□	Accepted
18.	DQ-FE-143	Dry Powder	5 Kg	N/A	■	□	Accepted
19.	DQ-FE-144	Water Based	25 L	N/A	■	□	Accepted
20.	DQ-FE-145	Dry Powder	25 Kg	N/A	■	□	Accepted
21.	DQ-FE-146	Dry Powder	25 Kg	N/A	■	□	Accepted
22.	DQ-FE-147	Dry Powder	25 Kg	N/A	■	□	Accepted
23.	DQ-FE-148	Dry Powder	25 Kg	N/A	■	□	Accepted
24.	DQ-FE-149	Dry Powder	25 Kg	N/A	■	□	Accepted
25.	DQ-FE-150	Dry Powder	25 Kg	N/A	■	□	Accepted

*This is to Certify That: a competent person did attend the above-mentioned owner's work location on the date shown above and the fire extinguishers described in this report have been Examined as per the requirements of NFPA10 Standard. The results at the time of Inspection found **satisfactory** and the above-mentioned extinguishers considered **safe** to continue in service.*

Fire Extinguishers Inspected By:

Hussein Alaa / Master Log Certificate (NEBOSH 0136995/38678)

Date: 20/April/2025

Signature:



Reviewed & approved by: Hasan Omran

