



## Fire Extinguishers Inspection Report

<b>Client:</b>	DPAB Co.Ltd Iraq Branch Block-9	<b>Job Number:</b>	ATS-04-25-4953
<b>Report Number:</b>	ATS-04-25-4953-007	<b>Location:</b>	DQ Base – Basra / Block 9
<b>Date of Inspection:</b>	20- Apr-2025	<b>Inspection Due Date:</b>	19- Apr-2026

<b>Relative Standard:</b>	NFPA (National Fire Protection Association)- NFPA 10: Standard For Portable Fire Extinguisher
---------------------------	---

<b>Environmental conditions during testing:</b>	Humidity 41.0 % Rh ±3%	Temperatures Mean: 36.0°C ±5°C
---	------------------------	--------------------------------

#	Serial Number	Type	Weight	Re-filling	Condition		Remarks
					Acc.	Rej.	
1.	DQ-FE-151	CO2	12 Kg	N/A	■	□	Accepted
2.	DQ-FE-152	Dry Powder	25 Kg	N/A	■	□	Accepted
3.	DQ-FE-153	Foam	25 L	N/A	■	□	Accepted
4.	DQ-FE-154	Dry Powder	2 Kg	N/A	■	□	Accepted
5.	DQ-FE-155	Dry Powder	2 Kg	N/A	■	□	Accepted
6.	DQ-FE-156	Dry Powder	2 Kg	N/A	■	□	Accepted
7.	DQ-FE-157	Dry Powder	2 Kg	N/A	■	□	Accepted
8.	DQ-FE-158	Dry Powder	2 Kg	N/A	■	□	Accepted

**This is to Certify That:** a competent person did attend the above-mentioned owner's work location on the date shown above and the fire extinguishers described in this report have been Examined as per the requirements of NFPA10 Standard. The results at the time of Inspection found **satisfactory** and the above-mentioned extinguishers considered **safe** to continue in service.

### Fire Extinguishers Inspected By:

Hussein Alaa / Master Log Certificate (NEBOSH 0136995/38678)

Date: 20/April/2025

Signature:



Reviewed & approved by: Hasan Omran

